

# TEST ATTESTATION

The Belgian Institute for Wood Technology (WOOD.BE) hereby certifies that the products tested in the range

## Parky “12mm” (Parky Deluxe / Parky Twist)

Placed on the market by

**Decospan NV**  
**Lageweg 33**  
**8930 Menen**

According to the following classification standard

**EN14354:2017**

Can be classified as

**Class 33**

With the classification requirements

**Resistance to indentation:  $\geq 40\text{N/mm}^2$**

**Thickness swelling:  $\leq 10\%$**

**Impact Resistance: EC3**


**Wear Resistance:  $\geq 6000$  revolutions**

**Locking Strength: Length  $\geq 1.0\text{kN/m}$ ; Short Side  $\geq 2.0\text{kN/m}$**

(see test reports: 2720196\* / 200034 / 2620020\*)

*\*tests conducted at external lab (NB)*

Brussels, 14th May 2020



Chris De Roock

General Manager WOOD.BE



**WOOD.BE**

This attestation relates only to the results and its field of application presented in the test report. This attestation is valid until 14/05/2021 and does not guarantee a future conformity of the product with the specifications of the here above mentioned standards

This attestation can only be distributed in full by facsimile with the permission of WOOD.BE.

**WOOD.BE** is the Belgian Institute for Wood Technology (previously CTIB-TCHN)  
Allée Hof ter Vleestdreef 3, 1070 Brussels  
info@wood.be – www.wood.be tel: +32 (0)2.558.15.50