

# TEST ATTESTATION

The Belgian Institute for Wood Technology (WOOD.BE) hereby certifies that the products tested in the range

## Parky “8.3mm” (Parky Lounge)

Placed on the market by

**Decospan NV**  
**Lageweg 33**  
**8930 Menen**

According to the following classification standard

**EN14354:2017**

Can be classified as

**Class 33**

With the classification requirements

**Resistance to indentation:  $\geq 40\text{N/mm}^2$**

**Thickness swelling:  $\leq 10\%$**

**Impact Resistance: EC3**


**Wear Resistance:  $\geq 6000$  revolutions**

**Locking Strength: Length  $\geq 1.0\text{kN/m}$ ; Short Side  $\geq 2.0\text{kN/m}$**

(see test reports: 2720196\* / 200034 / 2620020\*)

*\*tests conducted at external lab (NB)*

Brussels, 25th October 2021



Chris De Roock

General Manager WOOD.BE

This attestation relates only to the results and its field of application presented in the test report. This attestation is valid until 25/10/2022 and does not guarantee a future conformity of the product with the specifications of the here above mentioned standards

This attestation can only be distributed in full by facsimile with the permission of WOOD.BE.

**WOOD.BE** is the Belgian Institute for Wood Technology (previously CTIB-TCHN)  
Allée Hof ter Vleestdreef 3, 1070 Brussels  
info@wood.be – www.wood.be tel: +32 (0)2.558.15.50



**WOOD.BE**